

Day	pH	Alk	Phos	Other	Y/N
1	7.3				Y
2		plant	off		
3		plant	off		
4	7.2				Y
5	7.3				Y
6	7.3	38			Y
7	7.3				Y
8	7.3				Y
9	7.3				Y
10	7.3				Y
11	7.2				Y
12	7.5				Y
13	7.2	28			Y
14	7.4				Y
15	7.2				Y
16	7.3				Y
17	7.4				Y
18	7.3				Y
19		plant	off		
20	7.2	26			Y
21	7.2				Y
22	7.2				Y
23	7.2				Y
24	7.2				Y
25	7.2				Y
26	7.2				Y
27	7.3	30			Y
28	7.2				Y
29	7.3				Y
30	7.2				Y
31	7.3				Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	6	7	0
---	---	---	---	---

System Name: Port Orford, City of

Entry Point: 1635 Arizona St.

Sample Period: January, 2026
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk		<i>(Alkalinity)</i>
PO4		<i>(Orthophosphate)</i>
Other		<i>(_____)</i>

Print Name: Dave Terrusa

Signature: /S/ Dave Terrusa

Date: 2/5/2026

Send to DWP within 10 days after end of sampling period