

Day	pH	Alk	Phos	Other	Y/N
1	7.2				Y
2	7.3				Y
3	7.3				Y
4	7.3	31			Y
5	7.3				Y
6	7.2				Y
7	7.2				Y
8		Plant	Off		
9	7.2				Y
10	7.2	26			Y
11	7.2				Y
12	7.3				Y
13	7.3				Y
14	7.2				Y
15	7.2				Y
16	7.3				Y
17	7.4	26			Y
18	7.2				Y
19	7.2				Y
20	7.4				Y
21	7.2				Y
22		Plant	OFF		
23	7.2				Y
24		Plant	OFF		
25	7.3				Y
26	7.3	28			Y
27	7.2				Y
28	7.2				Y
29					Y
30					Y
31					Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	6	7	0
---	---	---	---	---

System Name: Port Orford, City of

Entry Point: 1635 Arizona St.

Sample Period: February, 2026
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<table border="1"><tr><td>7.2</td></tr></table>	7.2
7.2		
Alk	<table border="1"><tr><td></td></tr></table> * (Alkalinity)?	
PO4	<table border="1"><tr><td></td></tr></table> (Orthophosphate)	
Other	<table border="1"><tr><td></td></tr></table> (

Print Name: DAVE TERRUSA

Signature: DAVE TERRUSA

Date: 9 MAR 2026

Send to DWP within 10 days after end of sampling period