

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.2				Y
2	7.3				Y
3	7.2	30			Y
4		Plant	Off		
5	7.2				Y
6	7.3				Y
7	7.2				Y
8	7.3				Y
9	7.4				Y
10	7.3	28			Y
11	7.2				Y
12	7.3				Y
13	7.2				Y
14		plant	off		
15	7.2				Y
16	7.3				Y
17	7.2	30			Y
18	7.2				Y
19	7.3				Y
20	7.2				Y
21	7.2				Y
22	7.2				Y
23	7.2				Y
24	7.2	28			Y
25	7.2				Y
26	7.2				Y
27	7.2				Y
28	7.3				Y
29	7.2				Y
30	7.2				Y
31	7.3	28			Y
(No N = Excursion) Total N's					Y

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 

0	0	6	7	0
---	---	---	---	---

System Name: Port Orford, City Of

Entry Point: 1635 Arizona St.

Sample Period: March 2026  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

For OHA use only

**Minimum Water Quality Parameters as set by**

pH 

7.2
-----

Alk 

--

 (Alkalinity)

PO4 

--

 (Orthophosphate)

Other 

--

 (

Print Name: Dave Terrusa

Signature: /S/ Dave Terrusa

Date: 04/06/26

Send to DWP within 10 days after end of sampling period