Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.3	45			Y
2	7.3	46			Y
3	7.5	41			Y
4	7.4	40			Y
5	7.3	40			Y
6	7.3	37			Y
7	7.3	40			Y
8	7.2	40			Y
9	7.2	38			Y
10	7.5	41			Y
11	7.3	40			Y
12	7.4	45			Y
13	off	off			Y
14	7.6	48			Y
15	7.3	42			Y
16	7.3	38			Y
17	7.3	40			Y
18	7.3	42			Y
19	7.2	45			Y
20	7.4	48			Y
21	7.4	45			Y
22	7.2	43			Y
23	7.4	46			Y
24	7.5	40			Y
25	7.4	45			Y
26	7.3	46			Y
27	7.3	44			Y
28	7.6	42			Y
29	7.3	45			Y
30	7.4	44			Y
31	7.4	45			Y

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day?

County: Coos Agency: REGION 2

ENTRY POINT

EP-A

PWS ID 4100672

POWERS, CITY OF

Sample period: January/2021
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Alk 34.0 *(Alkalinity)*

Print Name: Dave Terrusa

Signature: I have reviewed this document

Date & Phone#: (541) 253-7556 2021.02.03 15:57:50 -08'00'

Send to DWP within 10 days after end of sampling period