

Day	pH	Alk	Phos	Other	Y/N
1	7.9	63			Y
2	7.9	65			Y
3	7.8	60			Y
4	7.8	60			Y
5	7.6	54			Y
6	7.7	57			Y
7	7.6	57			Y
8	7.8	68			Y
9	8.0	67			Y
10	8.0	64			Y
11	7.8	64			Y
12	7.7	60			Y
13	7.7	63			Y
14	7.7	60			Y
15	7.7	57			Y
16	7.7	59			Y
17	8.0	61			Y
18	7.8	58			Y
19	7.7	56			Y
20	7.7	52			Y
21	7.7	58			Y
22	7.7	55			Y
23	7.6	53			Y
24	7.8	55			Y
25	7.8	40			Y
26	7.6	52			Y
27	7.7	55			Y
28	7.6	57			Y
29	7.7	58			Y
30	7.8	57			Y
31					

<<Have minimums been met for this day?

County: Coos Agency: REGION 2

ENTRY POINT

EP-A

PWS ID 4100672

POWERS, CITY OF

Sample period: September '22
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2
Alk 34.0 (Alkalinity)

Print Name: _____
Digitally signed by Dave Terrusa
DN: cn=Dave Terrusa, c=US, o=H2o System Consulting, ou=DRC,
email=treatment6930@gmail.com

Signature: _____
Reason: I have reviewed this document
Location: (541) 253-7556
Date: 2022.10.03 12:09:54 -07'00'

Date & Phone#: _____

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0