

Day	pH	Alk	Phos	Other	Y/N
1	7.8	59			Y
2	7.7	68			Y
3	7.5	56			Y
4	7.5	56			Y
5	7.5	63			Y
6	7.3	44			Y
7	7.4	58			Y
8	7.5	46			Y
9	7.4	47			Y
10	7.4	47			Y
11	7.4	47			Y
12	7.6	46			Y
13	7.6	50			Y
14	7.5	49			Y
15	7.8	58			Y
16	8.0	61			Y
17	7.9	55			Y
18	7.6	60			Y
19	8.10	51			Y
20	7.8	53			Y
21	7.6	53			Y
22	7.7	45			Y
23	7.5	45			Y
24	7.5	44			Y
25	7.5	50			Y
26	7.5	43			Y
27	7.5	45			Y
28	7.5	48			Y
29	7.5	46			Y
30	7.7	52			Y
31					

<<Have minimums been met for this day?

County: Coos Agency: REGION 2

**ENTRY POINT**  
**EP-A**  
**PWS ID 4100672**  
**POWERS, CITY OF**

Sample period: November 2022  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

**Reference**

Minimum Water Quality Parameter(s) as set by State:

pH 7.2  
Alk 34.0 (Alkalinity)

Print Name: \_\_\_\_\_  
Signature: \_\_\_\_\_  
Date & Phone#: \_\_\_\_\_

Digitally signed by Dave Terrusa  
DN: cn=Dave Terrusa, c=US, o=H2o System Consulting, ou=DRC,  
email=treatment6930@gmail.com  
Reason: I have reviewed this document  
Location: (541) 253-7556  
Date: 2022.12.02 11:26:55 -08'00'

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0