

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Other | Y/N |
|-----|-----|-----|------|-------|-----|
| 1 | 7.6 | 43 | | | Y |
| 2 | 7.6 | 45 | | | Y |
| 3 | 7.6 | 50 | | | Y |
| 4 | 7.7 | 46 | | | Y |
| 5 | 7.6 | 57 | | | Y |
| 6 | 7.8 | 48 | | | Y |
| 7 | 7.4 | 44 | | | Y |
| 8 | 7.5 | 43 | | | Y |
| 9 | 7.5 | 42 | | | Y |
| 10 | 7.5 | 42 | | | Y |
| 11 | 7.6 | 42 | | | Y |
| 12 | 7.6 | 40 | | | Y |
| 13 | 7.5 | 44 | | | Y |
| 14 | 7.5 | 43 | | | Y |
| 15 | 7.5 | 45 | | | Y |
| 16 | 7.6 | 43 | | | Y |
| 17 | 7.5 | 46 | | | Y |
| 18 | 7.7 | 52 | | | Y |
| 19 | 7.4 | 57 | | | Y |
| 20 | 7.5 | 43 | | | Y |
| 21 | 7.6 | 46 | | | Y |
| 22 | 7.5 | 43 | | | Y |
| 23 | off | off | | | |
| 24 | 7.8 | 48 | | | Y |
| 25 | 7.5 | 47 | | | Y |
| 26 | 7.5 | 42 | | | Y |
| 27 | 7.5 | 42 | | | Y |
| 28 | 7.4 | 38 | | | Y |
| 29 | | | | | |
| 30 | | | | | |
| 31 | | | | | |

<<Have minimums been met for this day?

County: Coos Agency: REGION 2

ENTRY POINT

EP-A

PWS ID 4100672

POWERS, CITY OF

Sample period: February 2022
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2
Alk 34.0 (Alkalinity)

Print Name: _____

Digitally signed by Dave Terrusa
DN: cn=Dave Terrusa, c=US, o=Water Treatment Systems, ou=DRC,
email=treatment6930@gmail.com

Signature: _____

Reason: I have reviewed this document and submit it for the record.
Location: PO Box 226, Langlois, OR, 97450
Date: 2023.03.03 11:28:40 -0800

Date & Phone#: _____

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0