

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5	43			Y
2	7.5	42			Y
3	7.6	45			X
4	7.6	45			Y
5	7.6	47			Y
6	7.6	45			Y
7	7.5	45			Y
8	7.6	43			Y
9	7.4	41			Y
10	7.6	42			Y
11	7.6	42			Y
12	7.5	42			Y
13	7.5	43			Y
14	7.5	46			Y
15	7.4	43			Y
16	7.6	46			Y
17	7.5	45			Y
18	7.5	46			Y
19	7.9	44			Y
20	7.5	41			Y
21	7.5	50			Y
22	7.5	39			Y
23	7.3	35			Y
24	7.5	42			Y
25	7.7	47			Y
26	8.1	50			Y
27	7.6	41			Y
28	off	off			off
29	off	off			off
30	off	off			off
31	7.4	46			Y

<<Have minimums been met for this day?

County: Coos Agency: REGION 2

ENTRY POINT

EP-A

PWS ID 4100672

POWERS, CITY OF

Sample period: March / 2023
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2
Alk 34.0 (Alkalinity)

Print Name: _____

Signature: _____

Date & Phone#: _____

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0