

Water Quality Parameter Monitoring Form  
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5	46			Y
2	7.6	45			Y
3	7.7	43			Y
4	7.7	42			Y
5	7.7	43			Y
6	7.7	45			Y
7	7.7	44			Y
8	7.6	43			Y
9	7.5	42			Y
10	7.5	40			Y
11	7.5	42			Y
12	7.5	42			Y
13	7.6	45			Y
14	7.5	41			Y
15	7.6	44			Y
16	7.6	43			Y
17	7.7	47			Y
18	7.7	54			Y
19	7.8	43			Y
20	7.9	54			Y
21	7.8	48			Y
22	7.6	44			Y
23	7.5	40			Y
24	7.5	51			Y
25	7.5	45			Y
26	7.6	46			Y
27	7.6	40			Y
28	7.6	45			Y
29	7.6	41			Y
30	7.6	47			Y
31	7.6	45			Y

<<Have minimums been met for this day?

County: Coos Agency: REGION 2

**ENTRY POINT**

**EP-A**

**PWS ID 4100672**

**POWERS, CITY OF**

Sample period: May 2023  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2  
Alk 34.0 (Alkalinity)

Print Name: Digitally signed by Dave Terrusa  
DN: cn=Dave Terrusa, c=US, o=Water Treatment Systems, ou=DRC,  
email=treatment6930@gmail.com

Signature: Reason: I Have reviewed this document and submit it for the record.  
Location: PO Box 226, Langlois, OR, 97450  
Date: 2023.06.09 15:09:17 -0700

Date & Phone#: \_\_\_\_\_

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0