

Day	pH	Alk	Phos	Other	Y/N
1	7.7	52			Y
2	7.7	53			Y
3	7.7	50			Y
4	7.7	53			Y
5	7.7	50			Y
6	7.4	37			Y
7	8.0	63			Y
8	7.7	51			Y
9	7.8	59			Y
10	7.6	52			Y
11	7.6	52			Y
12	7.6	52			Y
13	7.4	56			Y
14	7.6	51			Y
15	7.6	50			Y
16	7.6	50			Y
17	7.6	53			Y
18	7.6	52			Y
19	7.5	51			Y
20	7.5	53			Y
21	7.7	54			Y
22	7.5	62			Y
23	7.9	60			Y
24	7.5	50			Y
25	7.5	51			Y
26	7.7	58			Y
27	7.5	50			X
28	7.5	49			Y
29	7.4	47			Y
30	7.5	45			Y
31	7.3	46			Y

(No = N = Excursion) Total N's: 0

<<Have minimums been met for this day?

County: Coos Agency: REGION 2

ENTRY POINT

EP-A

PWS ID 4100672

POWERS, CITY OF

Sample period: July 1/2023
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2
Alk 34.0 (Alkalinity)

Print Name: Dave

Signature: Terrusa

Date & Phone#:

Send to DWP within 10 days after end of sampling period

Digitally signed by Dave Terrusa
DN: cn=Dave Terrusa, o=US, ou=Water Treatment Systems, ou=DRC, email=treatment830@gmail.com
Reason: I have reviewed this document and submit it for the record.
Location: PO Box 226, Langlois, OR, 97450
Date: 2023.08.04 21:12:50 -0700