

Day	pH	Alk	Phos	Other	Y/N
1	7.6	55			Y
2	7.7	52			Y
3	7.7	55			Y
4	7.9	65			Y
5	7.7	60			Y
6	7.6	62			Y
7	7.7	56			Y
8	7.7	55			Y
9	7.7	55			Y
10	7.7	57			Y
11	7.7	58			Y
12	7.7	54			Y
13	7.7	57			Y
14	7.6	55			Y
15	7.5	57			Y
16	7.5	56			Y
17	7.5	56			Y
18	7.6	55			Y
19	7.6	67			Y
20	7.8	64			Y
21	7.6	59			Y
22	7.7	59			Y
23	7.7	57			Y
24	7.8	58			Y
25	7.7	60			Y
26	7.6	61			Y
27	7.7	60			Y
28	7.7	55			Y
29	7.7	63			Y
30	7.7	61			Y
31	7.7	60			Y

(No = N = Excursion) Total N's **0**

<<Have minimums been met for this day?

County: Coos Agency: REGION 2

ENTRY POINT
EP-A
PWS ID 4100672
POWERS, CITY OF

Sample period: August 2023
Month/Year

Number of excursions during this month: **0**

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH **7.2**
Alk **34.0** (Alkalinity)

Print Name: Dave Terrusa
Signature: Terrusa
Date & Phone#:

Digitally signed by Dave Terrusa
DN: cn=Dave Terrusa, c=US, ou=Water Treatment Systems, ou=ORC,
email=d.terrusa@coos.gov
Reason: I have reviewed this document and submit it for the record.
Location: PO Box 226, Langlois, OR, 97450
Date: 2023.09.05 16:45:49 -0700

Send to DWP within 10 days after end of sampling period