

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.80	58			Y
2	7.7	59			Y
3	7.6	60			Y
4	7.7	56			Y
5	7.7	61			Y
6	7.5	52			Y
7	7.6	60			Y
8	7.9	65			Y
9	7.4	66			Y
10	7.8	68			Y
11	7.6	59			Y
12	7.6	63			Y
13	7.7	60			Y
14	7.7	60			Y
15	7.7	61			Y
16	7.6	60			Y
17	7.7	61			Y
18	7.8	63			Y
19	7.8	62			Y
20	7.8	67			Y
21	7.8	63			Y
22	7.9	65			Y
23	7.9	61			Y
24	7.9	62			Y
25	7.8	63			Y
26	7.8	60			Y
27	7.8	50			Y
28	7.6	50			Y
29	7.6	51			Y
30	7.8	62			Y
31					

<<Have minimums been met for this day?

County: Coos Agency: REGION 2

ENTRY POINT
EP-A
PWS ID 4100672
POWERS, CITY OF

Sample period: September 2023
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2
Alk 34.0 (Alkalinity)

Print Name: Dave Terrusa
Signature: Terrusa
Date & Phone#:

Digitally signed by Dave Terrusa
DN: cn=Dave Terrusa, c=US, o=Water Treatment Systems, ou=ORC, email=tterrusa@water-treatment.com
submit it for the record.
Location: PO Box 226, Langlois, OR, 97450
Date: 2023.10.05 10:49:52 -0700

(No = N = Excursion) Total N's 0