

Day	pH	Alk	Phos	Other	Y/N
1	7.6	55			Y
2	7.5	48			Y
3	7.5	48			Y
4	7.6	51			Y
5	7.7	52			Y
6	7.6	49			Y
7	7.5	52			Y
8	7.7	56			Y
9	7.8	57			Y
10	7.9	60			Y
11	7.9	60			Y
12	7.8	60			Y
13	7.9	57			Y
14	7.8	63			Y
15	8.2	62			Y
16	7.8	60			Y
17	7.4	60			Y
18	7.8	61			Y
19	7.3	60			Y
20	7.7	60			Y
21	7.7	60			Y
22	7.7	64			Y
23	7.8	55			Y
24	7.8	60			Y
25	8.0	60			Y
26	7.8	63			Y
27	7.9	61			Y
28	7.8	57			Y
29	7.8	59			Y
30	7.8	55			Y
31	7.7	56			Y

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day?

County: Coos Agency: REGION 2

**ENTRY POINT**  
**EP-A**  
**PWS ID 4100672**  
**POWERS, CITY OF**

Sample period: October 2023  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2  
Alk 34.0 (Alkalinity)

Print Name: Dave Terrusa  
Signature: Terrusa  
Date & Phone#: \_\_\_\_\_

Digitally signed by Dave Terrusa  
DN: cn=Dave Terrusa, c=US, o=Water  
Treatment Systems, ou=DRC,  
email=terrused950@gmail.com  
Reason: I have reviewed this document and  
submit it for the record.  
Location: P.O. Box 226, Langlois, OR, 97450  
Date: 2023.11.07 06:08:37 -0800

Send to DWP within 10 days after end of sampling period