

Day	pH	Alk	Phos	Other	Y/N
1	8.10	64			Y
2	7.9	63			Y
3	7.9	58			Y
4	7.6	53			Y
5	7.6	49			Y
6	7.7	50			Y
7	7.7	45			Y
8	7.5	43			Y
9	7.5	47			Y
10	7.5	43			Y
11	7.5	45			Y
12	7.6	45			Y
13	7.5	50			Y
14	7.8	50			Y
15	7.7	48			Y
16	7.8	62			Y
17	7.8	65			Y
18	7.7	50			Y
19	7.6	65			Y
20	7.7	63			Y
21	7.5	53			Y
22	7.6	50			Y
23	7.5	51			Y
24	7.8	50			Y
25	7.7	57			Y
26	7.5	49			Y
27	7.6	50			Y
28	7.6	47			Y
29	7.6	45			Y
30	7.6	47			Y
31	7.7	45			Y

<<Have minimums been met for this day?

County: Coos Agency: REGION 2

**ENTRY POINT**

**EP-A**

**PWS ID 4100672**

**POWERS, CITY OF**

Sample period: December 2023  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

**Reference**

Minimum Water Quality Parameter(s) as set by State:

pH 7.2  
Alk 34.0 (Alkalinity)

Print Name: David Terrusa

Signature: /S/ David Terrusa

Date & Phone#: 6 Jan 2024 - 541.253.7556

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0