

| Day | pH | Alk | Phos | Other | Y/N |
|-----|-----|-----|------|-------|-----|
| 1 | 7.5 | 45 | | | Y |
| 2 | 7.5 | 47 | | | Y |
| 3 | 7.6 | 45 | | | Y |
| 4 | 7.5 | 47 | | | Y |
| 5 | 7.6 | 47 | | | Y |
| 6 | 7.6 | 45 | | | Y |
| 7 | 7.6 | 43 | | | Y |
| 8 | 7.6 | 43 | | | Y |
| 9 | 7.5 | 46 | | | Y |
| 10 | 7.5 | 39 | | | Y |
| 11 | 7.5 | 42 | | | Y |
| 12 | 7.5 | 45 | | | Y |
| 13 | 7.4 | 45 | | | Y |
| 14 | 7.7 | 45 | | | Y |
| 15 | 7.4 | 50 | | | Y |
| 16 | 7.4 | 40 | | | Y |
| 17 | 7.5 | 43 | | | Y |
| 18 | 7.3 | 40 | | | Y |
| 19 | 7.5 | 41 | | | Y |
| 20 | 7.5 | 45 | | | Y |
| 21 | 7.6 | 46 | | | Y |
| 22 | 7.6 | 50 | | | Y |
| 23 | 7.8 | 55 | | | Y |
| 24 | 7.4 | 45 | | | Y |
| 25 | 7.4 | 44 | | | Y |
| 26 | 7.5 | 57 | | | Y |
| 27 | 7.9 | 53 | | | Y |
| 28 | 7.9 | 60 | | | Y |
| 29 | 7.4 | 43 | | | Y |
| 30 | 7.7 | 62 | | | Y |
| 31 | 7.7 | 58 | | | Y |

<<Have minimums been met for this day?

County: Coos Agency: REGION 2

ENTRY POINT

EP-A

PWS ID 4100672

POWERS, CITY OF

Sample period: January 2023
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2
Alk 34.0 (Alkalinity)

Print Name: David Terrusa

Signature: /S/ David Terrusa

Date & Phone#: 2/1/2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0