

Day	pH	Alk	Phos	Other	Y/N
1	7.7	60			Y
2	7.8	65			Y
3	7.8	62			Y
4	7.7	55			Y
5	7.7	53			Y
6	7.8	52			Y
7	7.8	57			Y
8	8.0	61			Y
9	7.8	55			Y
10	7.7	50			Y
11	7.8	49			Y
12	8.0	51			Y
13	7.9	61			Y
14	7.8	55			Y
15	7.8	50			Y
16	8.0	63			Y
17	7.7	60			Y
18	8.0	62			Y
19	7.6	60			Y
20	7.8	57			Y
21	7.8	56			Y
22	7.7	59			Y
23	7.8	55			Y
24	7.8	55			Y
25	7.9	60			Y
26	7.9	55			Y
27	7.8	57			Y
28	7.8	60			Y
29	7.8	59			Y
30					
31					

(No = N = Excursion) Total N's 0

<p><<Have minimums been met for this day?</p>	<p>County: Coos Agency: REGION 2</p> <p style="text-align: center;">ENTRY POINT</p> <p style="text-align: center;">EP-A</p> <p style="text-align: center;">PWS ID 4100672</p> <p style="text-align: center;">POWERS, CITY OF</p> <p style="text-align: center;">Sample period: <u>Feb 2024</u></p> <p style="text-align: center;">Month/Year</p>
---	--

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

<p>Reference</p> <p>Minimum Water Quality Parameter(s) as set by State:</p> <p>pH 7.2</p> <p>Alk 34.0 (Alkalinity)</p>
--

Print Name: _____

Signature: _____

Date & Phone#: _____

Send to DWP within 10 days after end of sampling period