



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.8	53			Y
2	7.7	50			Y
3	7.7	47			Y
4	7.6	44			Y
5	7.6	45			Y
6	7.7	49			Y
7	7.8	47			Y
8	7.6	51			Y
9	7.7	53			Y
10	7.8	51			Y
11	7.8	52			Y
12	7.7	50			Y
13	7.7	47			Y
14	7.7	50			Y
15	7.7	50			Y
16	7.8	50			Y
17	7.8	50			Y
18	7.9	54			Y
19	7.7	48			Y
20	7.9	55			Y
21	8.1	56			Y
22	7.6	50			Y
23	7.9	55			Y
24	7.7	46			Y
25	7.7	46			Y
26	7.7	47			Y
27	7.7	48			Y
28	7.7	52			Y
29	7.7	50			Y
30	7.7	47			Y
31					

<<Have minimums been met for this day?

County: Coos Agency: REGION 2

ENTRY POINT
EP-A
PWS ID 4100672
POWERS, CITY OF

Sample period: April 2024
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2
Alk 34.0 (Alkalinity)

Print Name: _____
Signature: _____
Date & Phone#: _____

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0