



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5	53			Y
2	7.5	55			Y
3	7.6	56			Y
4	7.6	62			Y
5	7.5	57			Y
6	7.5	56			Y
7	7.5	55			Y
8	7.5	55			Y
9	7.5	55			Y
10	7.6	56			Y
11	7.6	55			Y
12	7.5	55			Y
13	7.5	59			Y
14	7.5	57			Y
15	7.7	60			Y
16	7.5	56			Y
17	7.5	56			Y
18	7.5	55			Y
19	7.5	55			Y
20	7.5	53			Y
21	7.5	55			Y
22	7.9	68			Y
23	7.6	59			Y
24	7.6	64			Y
25	7.4	60			Y
26	7.4	48			Y
27	7.4	47			Y
28	7.4	56			Y
29	7.4	54			Y
30	7.5	57			Y
31	7.5	60			Y

<<Have minimums been met for this day?	County: Coos Agency: REGION 2 <h2 style="text-align: center;">ENTRY POINT</h2> <h3 style="text-align: center;">EP-A</h3> <p style="text-align: center;">PWS ID 4100672</p> <p style="text-align: center;">POWERS, CITY OF</p> <p style="text-align: center;">Sample period: <u>August 2024</u> <small>Month/Year</small></p>
---	---

Number of excursions during this month: 0

(Over 9 excursions in 8 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference Minimum Water Quality Parameter(s) as set by State: pH <table border="1" style="display: inline-table;"><tr><td style="text-align: center;">7.2</td></tr></table> Alk <table border="1" style="display: inline-table;"><tr><td style="text-align: center;">34.0</td></tr></table> (Alkalinity)	7.2	34.0
7.2		
34.0		

Print Name: _____

Signature: _____

Date & Phone#: _____

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's

0
