

| Day | pH | Alk | Phos | Other | Y/N |
|-----|-----|-----|------|-------|-----|
| 1 | 7.4 | 50 | | | Y |
| 2 | 7.8 | 57 | | | Y |
| 3 | 7.6 | 52 | | | Y |
| 4 | 7.7 | 52 | | | Y |
| 5 | 7.7 | 55 | | | Y |
| 6 | 7.7 | 55 | | | Y |
| 7 | 7.4 | 58 | | | Y |
| 8 | 7.7 | 56 | | | Y |
| 9 | 8.0 | 52 | | | Y |
| 10 | 7.9 | 60 | | | Y |
| 11 | 7.9 | 58 | | | Y |
| 12 | 7.8 | 57 | | | Y |
| 13 | 7.9 | 57 | | | Y |
| 14 | 7.9 | 59 | | | Y |
| 15 | 7.7 | 62 | | | Y |
| 16 | 7.4 | 54 | | | Y |
| 17 | 7.9 | 48 | | | Y |
| 18 | 7.4 | 45 | | | Y |
| 19 | 7.4 | 56 | | | Y |
| 20 | 7.7 | 57 | | | Y |
| 21 | off | off | | | |
| 22 | 7.7 | 53 | | | Y |
| 23 | 7.5 | 55 | | | Y |
| 24 | 7.5 | 50 | | | Y |
| 25 | 7.5 | 48 | | | Y |
| 26 | 7.4 | 46 | | | Y |
| 27 | 7.4 | 45 | | | Y |
| 28 | 7.4 | 54 | | | Y |
| 29 | 7.7 | 52 | | | Y |
| 30 | 7.5 | 52 | | | Y |
| 31 | 7.6 | 47 | | | Y |

<<Have minimums been met for this day?

County: Coos Agency: REGION 2

ENTRY POINT
EP-A
PWS ID 4100672
POWERS, CITY OF

Sample period: December 2024
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2
Alk 34.0 (Alkalinity)

Print Name: David Terrusa
Signature: /s/ David Terrusa
Date & Phone#: 4 Jan 2025 (541) 253-7556

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0