

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.2	50			Y
2	7.4	57			Y
3	7.3	56			Y
4	7.3	51			Y
5	7.5	55			Y
6	7.4	55			Y
7	7.6	65			Y
8	7.4	50			Y
9	7.6	53			Y
10	7.8	57			Y
11	7.7	60			Y
12	7.5	57			Y
13	7.6	50			Y
14	7.7	60			Y
15	7.5	57			Y
16	7.5	49			Y
17	7.7	55			Y
18	7.8	60			Y
19	7.7	58			Y
20	7.6	61			Y
21	7.7	52			Y
22	7.7	55			Y
23	7.9	54			Y
24	7.8	61			Y
25	7.8	51			Y
26	7.8	50			Y
27	7.8	47			Y
28	7.8	48			Y
29	7.6	48			Y
30	7.6	46			Y
31	7.6	46			Y

(No = N = Excursion) Total N's 0

<<Have  
minimums  
been met for  
this day?

County: Coos

Agency: REGION 2

**ENTRY POINT**

**EP-A**

**PWS ID 4100672**

**POWERS, CITY OF**

Sample period: January 2025  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

### Reference

Minimum Water Quality  
Parameter(s) as set by State:

pH 7.2  
Alk 34.0 (Alkalinity)

Print Name: \_\_\_\_\_

Signature: \_\_\_\_\_

Date & Phone#: \_\_\_\_\_

Send to DWP within 10 days after end of  
sampling period