

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5	57			Y
2	7.5	59			Y
3	7.5	55			Y
4	7.5	55			Y
5	7.6	55			Y
6	7.6	54			Y
7	7.5	60			Y
8	7.5	55			Y
9	7.5	60			Y
10	7.6	55			Y
11	7.5	61			Y
12	7.5	56			Y
13	7.5	60			Y
14	7.5	60			Y
15	7.6	66			Y
16	7.6	65			Y
17	7.5	66			Y
18	7.7	65			Y
19	7.6	65			Y
20	7.6	65			Y
21	7.4	65			Y
22	7.5	61			Y
23	7.6	61			Y
24	7.6	62			Y
25	7.5	63			Y
26	7.5	61			Y
27	7.5	62			Y
28	7.6	62			Y
29	7.5	60			Y
30	7.6	61			Y
31	7.6	63			Y

<<Have minimums been met for this day?

County: Coos

Agency: REGION 2

**ENTRY POINT**

**EP-A**

**PWS ID 4100672**

**POWERS, CITY OF**

Sample period: July 2025

Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

### Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Alk 34.0 (Alkalinity)

Print Name: \_\_\_\_\_

Signature: \_\_\_\_\_

Date & Phone#: \_\_\_\_\_

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0