

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5	56			Y
2	7.5	58			Y
3	7.5	60			Y
4	7.5	63			Y
5	7.5	58			Y
6	7.5	58			Y
7	7.5	68			Y
8	7.4	55			Y
9	7.5	57			Y
10	7.7	51			Y
11	7.7	52			Y
12	7.6	53			Y
13	7.7	55			Y
14	7.6	61			Y
15	7.5	55			Y
16	7.6	58			Y
17	7.5	55			Y
18	7.5	48			Y
19	7.5	49			Y
20	7.5	50			Y
21	7.5	51			Y
22	7.3	54			Y
23	7.7	60			Y
24	7.6	53			Y
25	7.6	60			Y
26	7.6	56			Y
27	7.5	56			Y
28	7.5	55			Y
29	7.5	57			Y
30	7.9	63			Y
31					

(No = N = Excursion) Total N's **0**

<<Have
minimums
been met for
this day?

County: Coos

Agency: REGION 2

ENTRY POINT

EP-A

PWS ID 4100672

POWERS, CITY OF

Sample period: November 2025
Month/Year

Number of excursions during this month: **0**

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality
Parameter(s) as set by State:

pH **7.2**

Alk **34.0** (Alkalinity)

Print Name: _____

Signature: _____

Date & Phone#: _____

Send to DWP within 10 days after end of
sampling period