



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.0	40			Y
2	8.0	44			Y
3	8.1	42			Y
4	8.1	45			Y
5	7.9	45			Y
6	7.9	48			Y
7	8.0	50			Y
8	8.1	47			Y
9	7.8	47			Y
10	7.9	42			Y
11	7.9	40			Y
12	7.8	42			Y
13	7.8	40			Y
14	7.9	43			Y
15	7.9	40			Y
16	8.0	40			Y
17	8.0	42			Y
18	8.1	43			Y
19	8.1	46			Y
20	8.0	45			Y
21	8.1	50			Y
22	7.7	50			Y
23	7.9	58			Y
24	8.0	40			Y
25	7.9	38			Y
26	8.0	35			Y
27	8.0	37			Y
28	8.0	41			Y
29					
30					
31					

<<Have minimums been met for this day?

County: Coos Agency: REGION 2

**ENTRY POINT**

**EP-A**

**PWS ID 4100672**

**POWERS, CITY OF**

Sample period: February 2026  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

**Reference**

Minimum Water Quality Parameter(s) as set by State:

pH 7.2  
Alk 34.0 (Alkalinity)

Print Name: DAVE TERRUSA

Signature: [Signature]

Date & Phone#: 9 Mar 2026 541-253-7586

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0