

Day	pH	Alk	Phos	Other	Y/N
1	8.1	50			Y
2	8.1	53			Y
3	8.1	55			Y
4	8.1	56			Y
5	7.9	58			Y
6	7.9	50			Y
7	7.9	49			Y
8	7.9	52			Y
9	7.9	51			Y
10	7.9	52			Y
11	7.9	57			Y
12	7.9	54			Y
13	7.9	53			Y
14	7.9	47			Y
15	7.9	43			Y
16	7.9	42			Y
17	7.9	44			Y
18	7.8	45			Y
19	7.8	42			Y
20	7.9	40			Y
21	7.9	45			Y
22	7.9	42			Y
23	7.9	41			Y
24	7.8	47			Y
25	8.0	49			Y
26	8.0	44			Y
27	7.9	46			Y
28	7.9	47			Y
29	7.8	51			Y
30	7.8	52			Y
31					

<<Have minimums been met for this day?

County: Coos Agency: REGION 2

**ENTRY POINT**

**EP-A**

**PWS ID 4100672**

**POWERS, CITY OF**

Sample period: April 2026  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

**Reference**

Minimum Water Quality Parameter(s) as set by State:

pH 7.2  
Alk 34.0 (Alkalinity)

Print Name: \_\_\_\_\_

Signature: \_\_\_\_\_

Date & Phone#: \_\_\_\_\_

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0