

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.3	66			Y
2	7.2	59			Y
3	7.2	60			Y
4	7.2	55			Y
5	7.3	55			Y
6	7.2	54			X
7	7.2	62			Y
8	7.3	61			Y
9	7.3	63			Y
10	7.5	62			X
11	7.3	60			Y
12	7.2	56			X
13	7.3	65			Y
14	7.4	65			Y
15	7.8	72			Y
16	8.1	71			Y
17	7.9	70			Y
18	7.9	94			Y
19	7.8	74			Y
20	7.7	68			Y
21	7.5	65			Y
22	7.5	62			Y
23	7.5	63			Y
24	off	off			
25	7.8	68			Y
26	7.6	60			Y
27	7.7	60			Y
28	7.6	67			Y
29	7.6	65			Y
30	7.6	68			Y
31	7.7	65			Y

(No = N = Excursion) Total N's: **0**

<<Have
minimums
been met for
this day?

County: Coos

Agency: REGION 2

ENTRY POINT

EP-A

PWS ID 4100672

POWERS, CITY OF

Sample period: July 1, 2021
Month/Year

Number of excursions during this month: **0**

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

Minimum Water Quality
Parameter(s) as set by State:

pH **7.2**

Alk **34.0** (Alkalinity)

Print Name: _____

Signature: _____

Date & Phone#: _____

Send to DWP within 10 days after end of
sampling period