



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

| Day | pH  | Alk | Phos | Sili | Y/N |
|-----|-----|-----|------|------|-----|
| 1   | 7.5 |     |      |      | ✓   |
| 2   | 7.5 |     |      |      | ✓   |
| 3   | 7.5 |     |      |      | ✓   |
| 4   | 7.3 |     |      |      | ✓   |
| 5   | 7.6 |     |      |      | ✓   |
| 6   | 7.6 |     |      |      | ✓   |
| 7   | 7.4 |     |      |      | ✓   |
| 8   | 7.5 |     |      |      | ✓   |
| 9   | 7.5 |     |      |      | ✓   |
| 10  | 7.5 |     |      |      | ✓   |
| 11  | 7.5 |     |      |      | ✓   |
| 12  | 7.5 |     |      |      | ✓   |
| 13  | 7.5 |     |      |      | ✓   |
| 14  | 7.5 |     |      |      | ✓   |
| 15  | 7.6 |     |      |      | ✓   |
| 16  | 7.6 |     |      |      | ✓   |
| 17  | 7.6 |     |      |      | ✓   |
| 18  | 7.5 |     |      |      | ✓   |
| 19  | 7.5 |     |      |      | ✓   |
| 20  | 7.6 |     |      |      | ✓   |
| 21  | 7.6 |     |      |      | ✓   |
| 22  | 7.3 |     |      |      | ✓   |
| 23  | 7.5 |     |      |      | ✓   |
| 24  | 7.4 |     |      |      | ✓   |
| 25  | 7.5 |     |      |      | ✓   |
| 26  | 7.6 |     |      |      | ✓   |
| 27  | 7.5 |     |      |      | ✓   |
| 28  | 7.5 |     |      |      | ✓   |
| 29  |     |     |      |      |     |
| 30  |     |     |      |      |     |
| 31  |     |     |      |      |     |

<<Have minimums been met for this day?

County: Douglas Agency: S

**ENTRY POINT**

A.

PWS ID 4100699

REEDSPORT, CITY OF

Sample period: Feb 2021  
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2

Print Name: Jeff Blum

Signature: Jeff Blum

Date: 3-4-21

= N = Excursion) Total N's 0