



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.6				Y
2	7.7				Y
3	7.6				Y
4	7.5				Y
5	7.4				Y
6	7.5				Y
7	7.6				Y
8	7.7				Y
9	7.7				Y
10	7.7				Y
11	7.7				Y
12	7.5				Y
13	7.5				Y
14	7.6				Y
15	7.5				Y
16	7.6				Y
17	7.6				Y
18	7.5				Y
19	7.7				Y
20	7.6				Y
21	7.5				Y
22	7.6				Y
23	7.6				Y
24	7.5				Y
25	7.5				Y
26	7.4				Y
27	7.5				Y
28	7.5				Y
29	7.4				Y
30	7.5				Y
31	7.6				Y

<<Have minimums been met for this day?

County: Douglas Agency: S

ENTRY POINT.

A

PWS ID 4100699

REEDSPORT, CITY OF

Sample period: August 2021
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2

Print Name: Jeff Blum

Signature: JHB

Date: 9-2-21

0 = N = Excursion) Total N's 0