

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5				Y
2	7.5				Y
3	7.5				Y
4	7.4				Y
5	7.4				Y
6	7.4				Y
7	7.5				Y
8	7.6				Y
9	7.4				Y
10	7.5				Y
11	7.5				Y
12	7.5				Y
13	7.5				Y
14	7.5				Y
15	7.5				Y
16	7.5				Y
17	7.5				Y
18	7.6				Y
19	7.6				Y
20	7.6				Y
21	7.6				Y
22	7.5				Y
23	7.5				Y
24	7.6				Y
25	7.6				Y
26	7.6				Y
27	7.6				Y
28	7.7				Y
29					
30					
31					

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: City of Reedsport

Entry Point: A

Sample Period: February 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: Raymond Dunlap

Signature: Raymond Dunlap

Date: 03/01/23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's