

Day	pH	Alk	Phos	Other	Y/N
1	7.4				Y
2	7.4				Y
3	7.5				Y
4	7.5				Y
5	7.5				Y
6	7.5				Y
7	7.4				Y
8	7.4				Y
9	7.4				Y
10	7.5				Y
11	7.5				Y
12	7.5				Y
13	7.4				Y
14	7.4				Y
15	7.4				Y
16	7.4				Y
17	7.3				Y
18	7.3				Y
19	7.3				Y
20	7.3				Y
21	7.5				Y
22	7.4				Y
23	7.5				Y
24	7.4				Y
25	7.4				Y
26	7.4				Y
27	7.4				Y
28	7.4				Y
29	7.4				Y
30	7.4				Y
31					

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 00699

System Name: City of Reedsport

Entry Point: A

Sample Period: November 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk *(Alkalinity)*

PO4 *(Orthophosphate)*

Other ()

Print Name: Mike Woolley

Signature: *Michael Woolley*

Date: 12/06/23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0