

| Day | pH  | Alk | Phos | Other | Y/N |
|-----|-----|-----|------|-------|-----|
| 1   | 7.3 |     |      |       | Y   |
| 2   | 7.3 |     |      |       | Y   |
| 3   | 7.3 |     |      |       | Y   |
| 4   | 7.3 |     |      |       | Y   |
| 5   | 7.4 |     |      |       | Y   |
| 6   | 7.4 |     |      |       | Y   |
| 7   | 7.3 |     |      |       | Y   |
| 8   | 7.3 |     |      |       | Y   |
| 9   | 7.3 |     |      |       | Y   |
| 10  | 7.3 |     |      |       | Y   |
| 11  | 7.3 |     |      |       | Y   |
| 12  | 7.3 |     |      |       | Y   |
| 13  | 7.4 |     |      |       | Y   |
| 14  | 7.4 |     |      |       | Y   |
| 15  | 7.5 |     |      |       | Y   |
| 16  | 7.5 |     |      |       | Y   |
| 17  | 7.5 |     |      |       | Y   |
| 18  | 7.5 |     |      |       | Y   |
| 19  | 7.5 |     |      |       | Y   |
| 20  | 7.4 |     |      |       | Y   |
| 21  | 7.5 |     |      |       | Y   |
| 22  | 7.5 |     |      |       | Y   |
| 23  | 7.4 |     |      |       | Y   |
| 24  | 7.4 |     |      |       | Y   |
| 25  | 7.4 |     |      |       | Y   |
| 26  | 7.5 |     |      |       | Y   |
| 27  | 7.5 |     |      |       | Y   |
| 28  | 7.5 |     |      |       | Y   |
| 29  | 7.4 |     |      |       | Y   |
| 30  | 7.4 |     |      |       | Y   |
| 31  | 7.4 |     |      |       | Y   |

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41

System Name: City of Reedsport

Entry Point: A

Sample Period: December  
 Month/Year

Number of excursions\* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

|       |                                  |                  |
|-------|----------------------------------|------------------|
| pH    | <input type="text" value="7.2"/> |                  |
| Alk   | <input type="text"/>             | (Alkalinity)     |
| PO4   | <input type="text"/>             | (Orthophosphate) |
| Other | <input type="text"/>             | ( )              |

Print Name: Michael Woolley

Signature: [Signature]

Date: 1/3/2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's