

Day	pH	Alk	Phos	Other	Y/N
1	7.4				Y
2	7.3				Y
3	7.4				Y
4	7.4				Y
5	7.4				Y
6	7.4				Y
7	7.4				Y
8	7.4				Y
9	7.4				Y
10	7.4				Y
11	7.4				Y
12	7.4				Y
13	7.4				Y
14	7.4				Y
15	7.5				Y
16	7.4				Y
17	7.3				Y
18	7.4				Y
19	7.4				Y
20	7.4				Y
21	7.4				Y
22	7.4				Y
23	7.4				Y
24	7.4				Y
25	7.5				Y
26	7.4				Y
27	7.4				Y
28	7.3				Y
29	7.3				Y
30	7.3				Y
31	7.3				Y

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41

System Name: City of Reedsport

Entry Point: A

Sample Period: October 2024  
 Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

For OHA use only

**Minimum Water Quality Parameters as set by**

pH	<input type="text" value="7.2"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	( )

Print Name: Mike Wooley

Signature: Mike Wooley

Date: 11/05/2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's