

Day	pH	Alk	Phos	Other	Y/N
1	7.4				Y
2	7.4				Y
3	7.4				Y
4	7.4				Y
5	7.4				Y
6	7.4				Y
7	7.3				Y
8	7.3				Y
9	7.3				Y
10	7.3				Y
11	7.3				Y
12	7.3				Y
13	7.4				Y
14	7.3				Y
15	7.3				Y
16	7.3				Y
17	7.5				Y
18	7.3				Y
19	7.4				Y
20	7.4				Y
21	7.3				Y
22	7.3				Y
23	7.3				Y
24	7.3				Y
25	7.3				Y
26	7.4				Y
27	7.4				Y
28	7.3				Y
29	7.3				Y
30	7.3				Y
31	7.3				Y

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0 0 6 9 9

System Name: City of Reedsport

Entry Point: A

Sample Period:



Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: Mike Woolley

Signature: Mike Woolley

Date: 01/09/2025

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0