

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.3				Y
2	7.3				Y
3	7.3				Y
4	7.3				Y
5	7.3				Y
6	7.4				Y
7	7.3				Y
8	7.3				Y
9	7.3				Y
10	7.3				X
11	7.4				Y
12	7.4				Y
13	7.5				Y
14	7.6				Y
15	7.6				X
16	7.5				Y
17	7.6				Y
18	7.6				Y
19	7.6				Y
20	7.6				Y
21	7.6				Y
22	7.5				Y
23	7.6				Y
24	7.6				Y
25	7.6				Y
26	7.6				Y
27	7.5				Y
28	7.5				X
29	7.5				X
30	7.5				Y
31	7.6				Y

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0 0 6 9 9

System Name: City of Reedsport

Entry Point: A

Sample Period: January 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH 7.2
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: Mike Wooley

Signature: Mike Wooley

Date: 02/06/2025

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0