

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.6				Y
2	7.6				Y
3	7.6				Y
4	7.6				Y
5	7.6				Y
6	7.6				Y
7	7.6				Y
8	7.6				Y
9	7.6				Y
10	7.5				Y
11	7.6				Y
12	7.6				Y
13	7.6				Y
14	7.6				Y
15	7.5				Y
16	7.5				Y
17	7.5				Y
18	7.4				Y
19	7.4				Y
20	7.4				Y
21	7.5				Y
22	7.5				Y
23	7.5				Y
24	7.5				Y
25	7.5				Y
26	7.5				Y
27	7.6				Y
28	7.5				Y
29					
30					
31					

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

System Name: City of Reedsport

Entry Point: A

Sample Period: February 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: Mike Woolley
Signature: Mike Woolley
Date: 03/07/2025

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's