

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5				Y
2	7.5				Y
3	7.6				Y
4	7.6				Y
5	7.6				Y
6	7.6				Y
7	7.6				Y
8	7.7				Y
9	7.7				Y
10	7.6				Y
11	7.6				Y
12	7.7				Y
13	7.7				Y
14	7.7				Y
15	7.6				Y
16	7.6				Y
17	7.6				Y
18	7.5				Y
19	7.6				Y
20	7.7				Y
21	7.7				Y
22	7.7				Y
23	7.7				Y
24	7.6				Y
25	7.5				Y
26	7.5				Y
27	7.6				Y
28	7.6				Y
29	7.6				Y
30	7.6				Y
31	7.6				Y

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

System Name: City of Reedsport

Entry Point: A

Sample Period: March 2025
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH	7.2	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Mike Woolery

Signature: Mike Woolery

Date: 04/07/2025

Send to DWP within 10 days after end of
sampling period

No = N = Excursion) Total N's