

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.3				Y
2	7.3				Y
3	7.4				Y
4	7.4				Y
5	7.4				Y
6	7.4				Y
7	7.5				Y
8	7.5				Y
9	7.5				Y
10	7.5				Y
11	7.5				Y
12	7.5				Y
13	7.5				Y
14	7.5				Y
15	7.5				Y
16	7.5				Y
17	7.5				Y
18	7.5				Y
19	7.5				Y
20	7.5				Y
21	7.4				Y
22	7.4				Y
23	7.3				Y
24	7.3				Y
25	7.3				Y
26	7.3				Y
27	7.4				Y
28	7.4				Y
29	7.4				Y
30	7.4				Y
31	7.4				Y

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

System Name: City of Reedsport

Entry Point: A

Sample Period: May 2025
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: Mike Wooley

Signature: Mike Wooley

Date: 6/6/2025

Send to DWP within 10 days after end of sampling period

No = N = Excursion) Total N's