

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5				Y
2	7.4				Y
3	7.4				Y
4	7.4				Y
5	7.4				Y
6	7.4				Y
7	7.4				Y
8	7.4				Y
9	7.4				Y
10	7.4				Y
11	7.5				Y
12	7.4				Y
13	7.4				Y
14	7.4				Y
15	7.5				Y
16	7.4				Y
17	7.5				Y
18	7.4				Y
19	7.4				Y
20	7.4				Y
21	7.4				Y
22	7.4				Y
23	7.5				Y
24	7.4				Y
25	7.4				Y
26	7.4				Y
27	7.4				Y
28	7.4				Y
29	7.4				Y
30	7.4				Y
31	7.4				Y

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

System Name: City of Reedsport

Entry Point: A

Sample Period: July 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: Mike Wooley
Signature: Mike Wooley
Date: 08/07/2025

Send to DWP within 10 days after end of
sampling period

No = N = Excursion) Total N's