

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.3				Y
2	7.3				Y
3	7.4				Y
4	7.3				Y
5	7.3				Y
6	7.3				Y
7	7.3				X
8	7.3				Y
9	7.3				Y
10	7.3				Y
11	7.3				Y
12	7.3				Y
13	7.3				Y
14	7.4				Y
15	7.4				Y
16	7.4				Y
17	7.4				Y
18	7.4				Y
19	7.4				Y
20	7.5				Y
21	7.6				Y
22	7.6				Y
23	7.6				Y
24	7.6				Y
25	7.5				Y
26	7.5				Y
27	7.4				Y
28	7.5				Y
29	7.5				X
30	7.5				Y
31					

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

System Name: City of Reedsport

Entry Point: A

Sample Period: November 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
Alk (Alkalinity)
PO4 (Orthophosphate)
Other

Print Name: Michael Woolley
Signature: Michael Woolley
Date: 12/09/2025

Send to DWP within 10 days after end of
sampling period

lo = N = Excursion) Total N's 0