

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?	County: Tillamook Agency: REGION 1 ENTRY POINT A PWS ID 4100708 Rockaway Beach Water Dist. Sample Period: <u>Nov-22</u> Month/Year
1	7.6				Y		
2	7.5				Y		
3	7.5				Y		
4	7.5				Y		
5	7.6				Y		
6	7.8				Y		
7	7.8				Y		
8	7.8				Y		
9	7.8				Y		
10	7.8				Y		
11	7.8				Y		
12	7.8				Y		
13	7.7				Y		
14	7.7				Y		
15	7.7				Y		
16	7.8				Y		
17	7.8				Y		
18	7.8				Y		
19	7.8				Y		
20	7.5				Y		
21	7.5				Y		
22	7.6				Y		
23	7.6				Y		
24	7.6				Y		
25	7.6				Y		
26	7.6				Y		
27	7.5				Y		
28	7.8				Y		
29	7.6				Y		
30	7.6				Y		
31	7.7				Y		
(No = N = Excursions)						Total N's	0

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative), An 'excursion' is anyday in which water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2

Print Name: Luke Shepard

Signature:

Date: 11/1/22