

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.7				Y
2	7.8				Y
3	7.7				Y
4	7.7				Y
5	7.7				Y
6	7.6				Y
7	7.7				Y
8	7.7				Y
9	7.7				Y
10	7.8				Y
11	7.8				Y
12	7.8				Y
13	7.8				Y
14	7.7				Y
15	7.7				Y
16	7.7				Y
17	7.8				Y
18	7.7				Y
19	7.7				Y
20	7.7				Y
21	7.7				Y
22	7.8				Y
23	7.7				Y
24	7.7				Y
25	7.8				Y
26	7.8				Y
27	7.9				Y
28	7.9				Y
29	7.9				Y
30	7.9				Y
31	7.9				Y

<< Have
minimums
been met for
this day?

County: Tillamook Agency: REGION 1

ENTRY POINT

A

PWS ID 4100708

Rockaway Beach Water Dist.

Sample Period: Jul-24
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative), An 'excursion' is anyday in which water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2

Print Name: Luke Shepard
Signature: [Signature]
Date: 8/6/24

(No = N = Excursions)

Total N's 0

Send to DWP within 10 days after end of sampling period
DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone: (503) 732-4381 Website: www.ohd.hr.state.or.us/dwp