

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?	County: Tillamook Agency: REGION 1 ENTRY POINT B PWS ID 4100708 Rockaway Beach Water Dist. Sample Period: <u>Jun-25</u> Month/Year
1	OFF				Y		
2	OFF				Y		
3	OFF				Y		
4	OFF				Y		
5	OFF				Y		
6	OFF				Y		
7	OFF				Y		
8	OFF				Y		
9	OFF				Y		
10	OFF				Y		
11	OFF				Y		
12	OFF				Y		
13	OFF				Y		
14	OFF				Y		
15	OFF				Y		
16	OFF				Y		
17	OFF				Y		
18	OFF				Y		
19	OFF				Y		
20	OFF				Y		
21	OFF				Y		
22	OFF				Y		
23	OFF				Y		
24	OFF				Y		
25	OFF				Y		
26	OFF				Y		
27	OFF				Y		
28	OFF				Y		
29	OFF				Y		
30	OFF				Y		
31	OFF				Y		

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative), An 'excursion' is anyday in which water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2

Print Name: Luke Shepard

Signature:

Date: 2-Jun-25

(No = N = Excursions) **Total N's** 0