

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	OFF				Y
2	OFF				Y
3	OFF				Y
4	OFF				Y
5	OFF				Y
6	OFF				Y
7	OFF				Y
8	OFF				Y
9	OFF				Y
10	OFF				Y
11	OFF				Y
12	OFF				Y
13	OFF				Y
14	OFF				Y
15	OFF				Y
16	OFF				Y
17	OFF				Y
18	OFF				Y
19	OFF				Y
20	OFF				Y
21	OFF				Y
22	OFF				Y
23	OFF				Y
24	OFF				Y
25	OFF				Y
26	OFF				Y
27	OFF				Y
28	OFF				Y
29	OFF				Y
30	OFF				Y

<< Have
minimums
been met for
this day?

County: Tillamook Agency: REGION 1

ENTRY POINT

B

PWS ID 4100708

Rockaway Beach Water Dist.

Sample Period: Sep-25
Month/Year

Number of excursions during this month: 0


(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative), An 'excursion' is anyday in which water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2

Print Name: Luke Shepard

Signature: 

Date: 6-Oct-25

(No = N = Excursions)

Total N's

0

Send to DWP within 10 days after end of sampling period
DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone: (503) 732-4381 Website: www.ohd.hr.state.or.us/dwp