

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

ID #	Sample Location	pH	Alk	PO ₄	other	Y/N
1	105 N. 3 rd Ave	7.7				Y
2	276 Hwy 101 S	7.8				Y
3	105 N. 3 rd Ave	7.7				Y
4	276 Hwy 101 S	7.7				Y
(N = No = Excursion) Total N's						0

<Has sample met the minimums?

DISTRIBUTION

PWS ID: 41 0 0 7 0 8

System Name: Rockaway Beach Water

Dist.

Sample Period: August 2025

Month/Year

Sample Frequency: Every 36 Months

Distribution Samples required: 2
measurements from 2 DIST sites

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk		(Alkalinity)
-----	--	--------------

PO4	(Orthophosphate)
-----	------------------

Other	()
-------	-----

Print Name: Luke Shepard

Signature:

Date: 9-2-2025

Send to Drinking Water Program within 10 days after end of sampling period:

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>