

Day	pH	Alk	Phos	Other	Y/N
1	7.29				
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15	7.30				
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29	7.27				
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: City of St. Helens

Entry Point: A

Sample Period: October 2021
 Month/Year

Number of excursions* during this month: _____
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.0"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Print Name: Steven Wabschall

Signature: [Signature]

Date: 11/4/2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's