

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7					
8					
9					
10	7.36				
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24	7.42				
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41

System Name: City of St. Helens

Entry Point: A

Sample Period: December 2021  
 Month/Year

Number of excursions\* during this month: \_\_\_\_\_  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH	<input type="text" value="7.5"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Print Name: Steven Wabschall

Signature: [Signature]

Date: 1-7-2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's