

Day	pH	Alk	Phos	Other	Y/N
1	7.3				
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15	7.3				
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29	7.3				
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: City of St. Helens

Entry Point: A

Sample Period: 04 April 2022
Month/Year

Number of excursions* during this month: _____
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: Steve Wabschall

Signature: [Signature]

Date: 5/6/2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's