

## Water Quality Parameter Monitoring Form

## **Lead & Copper Rule Corrosion Control**

ID#	Sample Location	рН	Alk	P04	other	Y/N	<has sample<="" th=""></has>	
	City Shop	7.5	104			Υ	met the DISTRIBUTION minimums?	
	City Hall	7.9	102			Υ	PWS ID: 41 0 0 7 2 4	
	265 N. 15th St.	7.7	105			Υ	System Name: City of St. Helens	
	Old Portland Rd.	7.3	104			Υ		
	Ivy Ln. & N. Vernonia Rd	7,6	99			Υ	Sample Period: 08/2022  Month/Year	
	Kaster Rd @ Boise	7.5	102			Υ	Sample Frequency: 36 MONTHS	
	H.S. by concess stand	7.4	99			Υ	Distribution Samples required: 7	
							Number of excursions during this Sample Period =	
							(Number of locations when any WQP was less than the minimum.)	
							Note: Entry Point and Distribution Excursions are cumulative. Add Entry	
							Point and Distribution Excursions to get total for sample period.	
							For OHA use only	
							Minimum Water Quality Parameters as set by	
							pH 7.2 Alk (Alkalinity)	
							Alk (Alkalinity) PO4 (Orthophosphate)	
							Other (Onthophosphate)	
						-		
						9	Distance Ctl Civilian	
							Print Name: Ethan Stirling	
(N = No = Excursion) Total N's						Signature: <u>\$\frac{2}{100} \tag{7.67.022}</u>		

Send to Drinking Water Program within 10 days after end of sampling period:

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: http://healthoregon.org/dwp/