

# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

County: Marion Agency: REGION 1

	pH @ Aldersgate	Alkalinity @ Aldersgate	Y/N
	EP-A	EP-A	
Date	SU	mg/L	
3/1/2023	7.60	24.00	Y
3/2/2023	7.60	28.00	Y
3/3/2023	7.60	22.00	Y
3/4/2023	7.60	22.00	Y
3/5/2023	7.60	21.00	Y
3/6/2023	7.60	24.00	Y
3/7/2023	7.50	25.00	Y
3/8/2023	7.50	22.00	Y
3/9/2023	7.50	24.00	Y
3/10/2023	7.50	22.00	Y
3/11/2023	7.40	24.00	Y
3/12/2023	7.50	24.00	Y
3/13/2023	7.50	24.00	Y
3/14/2023	7.50	23.00	Y
3/15/2023	7.50	22.00	Y
3/16/2023	7.50	22.00	Y
3/17/2023	7.40	20.00	Y
3/18/2023	7.40	25.00	Y
3/19/2023	7.40	21.00	Y
3/20/2023	7.40	23.00	Y
3/21/2023	7.40	22.00	Y
3/22/2023	7.70	23.00	Y
3/23/2023	7.50	22.00	Y
3/24/2023	7.70	22.00	Y
3/25/2023	7.60	19.00	Y
3/26/2023	7.60	21.50	Y
3/27/2023	7.70	22.00	Y
3/28/2023	7.50	21.00	Y
3/29/2023	7.50	22.00	Y
3/30/2023	7.60	20.00	Y
3/31/2023	7.50	22.00	Y
(No=N=Excursion)	<b>Total N's</b>		0

<< Have minimums been met for the day?

### ENTRY POINT

EP-A

**PWS ID: 4100731**

**System name** City of Salem Public Works  
**Entry Point** Aldersgate  
**Sampling Period** March 2023

**Number of excursions during this month** none

(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months** none

(over 9 excursions in six months is a violation. Entry point and distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State**

pH	7.2
Alkalinity	15

**Print Name:** Dwayne Barnes  
**Signature:** \_\_\_\_\_  
**Date:** April 6, 2023