

# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

County: Marion Agency: REGION 1

	pH @ Aldersgate	Alkalinity @ Aldersgate	Y/N
	EP-A	EP-A	
Date	SU	mg/L	
5/1/2024	7.40	22.00	Y
5/2/2024	7.50	20.00	Y
5/3/2024	7.50	23.00	Y
5/4/2024	7.40	22.00	Y
5/5/2024	7.30	22.00	Y
5/6/2024	7.50	23.00	Y
5/7/2024	7.20	21.00	Y
5/8/2024	7.40	23.00	Y
5/9/2024	7.40	22.00	Y
5/10/2024	7.40	20.00	Y
5/11/2024	7.40	23.00	Y
5/12/2024	7.40	22.00	Y
5/13/2024	7.50	24.00	Y
5/14/2024	7.50	22.50	Y
5/15/2024	7.40	22.00	Y
5/16/2024	7.60	27.00	Y
5/17/2024	7.40	28.00	Y
5/18/2024	7.60	25.00	Y
5/19/2024	7.50	25.00	Y
5/20/2024	7.60	24.00	Y
5/21/2024	7.50	20.00	Y
5/22/2024	7.60	24.00	Y
5/23/2024	7.50	23.00	Y
5/24/2024	7.50	25.00	Y
5/25/2024	7.40	26.00	Y
5/26/2024	7.40	26.00	Y
5/27/2024	7.40	25.00	Y
5/28/2024	7.40	27.00	Y
5/29/2024	7.50	27.00	Y
5/30/2024	7.40	26.00	Y
5/31/2024	7.60	26.00	Y
(No=N=Excursion)	<b>Total N's</b>		0

<< Have minimums been met for the day?

### ENTRY POINT

EP-A

**PWS ID: 4100731**

**System name** City of Salem Public Works  
**Entry Point** Aldersgate  
**Sampling Period** May 2024

**Number of excursions during this month** none

(Count the number of days when any WQP was less than the minimum required)


**Total excursions during the previous 5 months** none

(over 9 excursions in six months is a violation. Entry point and distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State**

pH 7.2  
 Alkalinity 15

**Print Name:** Dwayne Barnes  
**Signature:**   
**Date:** June 7, 2024

Send to DWP within 10 days after end of sampling period  
 OHA-Drinking Water Program, PO Box 14350, Portland OR 97293-0350 Phone (971) 673-0405