

# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

County: Marion Agency: REGION 1

	pH @ Aldersgate	Alkalinity @ Aldersgate	Y/N
	EP-A	EP-A	
Date	SU	mg/L	
1/1/2025	7.20	20.00	Y
1/2/2025	7.50	22.00	Y
1/3/2025	7.40	23.00	Y
1/4/2025	7.40	22.00	Y
1/5/2025	7.50	26.00	Y
1/6/2025	7.60	27.00	Y
1/7/2025	7.50	27.00	Y
1/8/2025	7.60	27.00	Y
1/9/2025	7.50	27.00	Y
1/10/2025	7.30	28.00	Y
1/11/2025	7.30	26.00	Y
1/12/2025	7.30	26.00	Y
1/13/2025	7.20	27.00	Y
1/14/2025	7.70	30.00	Y
1/15/2025	7.50	30.00	Y
1/16/2025	7.40	28.00	Y
1/17/2025	7.30	31.00	Y
1/18/2025	7.50	31.00	Y
1/19/2025	7.80	30.00	Y
1/20/2025	8.00	28.00	Y
1/21/2025	7.80	28.50	Y
1/22/2025	7.70	28.00	Y
1/23/2025	7.70	22.00	Y
1/24/2025	7.60	24.00	Y
1/25/2025	7.40	22.00	Y
1/26/2025	7.40	24.00	Y
1/27/2025	7.40	23.00	Y
1/28/2025	7.50	23.00	Y
1/29/2025	7.30	22.00	Y
1/30/2025	7.30	24.00	Y
1/31/2025	7.40	25.00	Y
(No=N=Excursion)	<b>Total N's</b>		0

<< Have minimums been met for the day?

### ENTRY POINT

EP-A

**PWS ID: 4100731**

**System name** City of Salem Public Works  
**Entry Point** Aldersgate  
**Sampling Period** January 2025

**Number of excursions during this month** none

(Count the number of days when any WQP was less than the minimum required)


**Total excursions during the previous 5 months** none

(over 9 excursions in six months is a violation. Entry point and distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State**

pH 7.2  
 Alkalinity 15

**Print Name:** Dwayne Barnes  
**Signature:**   
**Date:** February 6, 2025